

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 6911-1288:161 Page 1 of 1

**CATEGORY:** Voice Communication Systems Control Units

**LISTEE:** Gamewell, 60 Pleasant Street, Ashland, MA 01721  
Contact: \*Brian Reynolds (203) 484-1200 \*FAX (203) 484-7309

**DESIGN:** Models GV-MP and GV-DP audio adjunct/voice evacuation systems. The GV-MP is the master panel in the system while the GV-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

GV-PWR-2A	Power Supply
GV-MFP	Master Fire Phone Card
GV-DCC	Data Communication Control Card
GV-ASC	Audio System Control Card
GV-SSC	Switch Scan Card
GV-MMC	Microphone Master Control Card
GV-IOI	Input/Output Card
GV-SLC	Switch and LED Card
GV-MFH	Master Fire Phone Handset Card
GV-MBR	Motherboard Card
GV-AMI	Audio Module Interface Card
GV-FPI	Fire Phone Interface Card
GV-MBK	Motherboard/Relay Card

**RATING:** 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as voice communication/evacuation/relocation/paging system for use with Evax's Models EVX-25 (CSFM Listing No. 6911-1446:100) or EVX-50 (CSFM Listing No. 6911-1446:102) and separately listed electrically compatible fire alarm control unit.

**XLF:** 6911-1446:103

\*Rev. 05-28-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**